RECISTERED ELECTRICAL ENGINEER DATE PROFES REVISED REVISED 10. 8249 Exp. 9/30/06 ELECTRICAL PB POWER, Inc. DATE A Parsons Brinckerhoff Company 303 Second St., Suite 700N San Francisco, CA 94107-1317 The State of California or its officers or agents shall not be responsible to the accuracy or completeness of electronic copies of this plan sheet. Caltrans now has a web site! To get to the web site, go to http://www.dot.ca.gov LUCAS HALIM SHEET NOTES: 1) For conduit to tower and suspension JEFFRI ELLERY S-2032/A12035cable lighting, see sheet E-230. Belvedere Bike Path lighting see Detail 2 on Dwg. E-165D 2 Roadway Barrier Receptacle, see Detail 1, sheet E-162. CY EBC 963 913 B 62 915 632 CALCULATED-DESIGNED BY NOTES: 1. References:

- For typical details and locations of conduit connections to light poles, barrier outlet boxes, call boxes, overhead sign lighting, CMS, CCTV and MVDS, see sheets E-160 thru E-162 and E-169.

- TOS equipment is shown for conduit routing only. For typical details of TOS controller and devices, see sheets E-344 through E-357.

- For types of pull boxes, splice boxes and enclosures, see sheet E-169.

- For circuit and conduit/cable tray schedules, see sheets starting NADELL BEHZAD (Typ) 68 schedules, see sheets starting at E-401. For Roadway Level Call Boxes, refer to sheet E-396. For Roadway level, Bike Path and Belvedere Lighting Fixture Schedules, see sheets E-146, E-147 and E-165. Bike Path lighting 3 see Detail 3 on Dwg. E-165E (typ) -Belvedere Bike Pdth lighting see Detdil on Dwg. E-165C For Roadway level and Bike Path Call Box Schedule, see sheet E-397. For number of lighting fixtures (main tower lights) see lighting schedule sheets E-271 and E-272. (126) 6. All conduits and fittings routed exposed between the Bike Path and the roadway shall be galvanized rigid steel, PVC coated. SAS Superstructure | Skyway Structure

is+ COUNTY 12.7/14.3, 61R1 84 04 SF,Ala 80 2/12/10 DATE REGISTERED ELECTRICAL ENGINEER DAVID H. OTO 5-10-2010 10699 PLANS APPROVAL DATE Exp.06/30/201 THE STATE OF CALIFORNIA OR ITS OFFICERS
OF AGENTS SHALL NOT BE RESPONSIBLE FOR
THE ACCURACY OR COMPLETENESS OF ELECTRONIC COPIES OF THIS PLAN SHEET.

PB AMERICAS, Inc. 303 Second St., Suite 700N San Francisco, CA 94107-1317

"CCO DRAFT"

08/25/2010

FOR ROADWAY LIGHTING POLES REFERENCE ONLY

FOR REDUCED PLANS ORIGINAL 0 20 40 60 80 SCALE IS IN MILLIMETERS

0. 11465

A dydy.

FOR REVISION ONLY

ROADWAY LIGHTING POLE LOCATION PLAN-SHEET 40 SAS SUPERSTRUCTURE

7. See sheets E-160 thru E-165 for conduit locations.

SAS SUPERSTRUCTURE ROADWAY EASTBOUND

LIGHTING AND ELECTRICAL SYSTEMS

DGN FILE =>T:\I3103\MS\pse\SFOBB Roadway Light Pole\CCO USERNAME =>Fusco

8. For Belvedere lighting fixture installation, see sheet E-173.

E-140

EA 0120F1

NO SCALE

E-59

RELATIVE BORDER SCALE IS IN MILLIMETERS USERNAME => fusco BORDER LAST REVISED 3/1/2007 DGN FILE => T:\13103\MS\pse\SFOBB Roadway Light Pole\CCO for SAS MEP\E-59R01.dgn

Contract 04-012024

ALL DIMENSIONS ARE IN METERS UNLESS OTHERWISE SHOWN

SAS SUPERSTRUCTURE - CONDUIT PLAN

TW RG 44 MP EL RR 42

BY CH'D CCO#

No. E 8651

FOR REVISION ONLY

 \triangle

REQUEST FOR INFORMATION NOT ADDRESSED IN THIS CCO REMAIN IN FORCE

DESCRIPTIONS

REV1S10NS

1 02/19/08 ELECTRICAL MODIFICATIONS

CONTRACT CHANGE ORDER NO.

THIS PLAN ACCURATE FOR ELECTRICAL WORK ONLY.

MARK DATE

SHEET ____OF __

Calt

DEPARTMENT

CAL IFORNIA

뇽

altans